

CENTRAL FIRE PROTECTION DISTRICT OF SANTA CRUZ COUNTY

Incident Media Release

**Date of Incident:** 05/04/10 **Dispatch Time:** 18:53

**Type of Incident:** Structure Fire  
**Location of Incident:** 3737 Coyote Canyon Road

**Brief Scenario of incident:** Central Fire was dispatched to an alarm sounding (thermal detector sounding in a garage) at the aforementioned address. While enroute the responding units were informed by the dispatch center there was a fire in the garage. The first arriving unit found smoke showing from a two story residential structure with a three car garage on the first floor. Fire crews entered the garage and found a small fire, being held in check by two residential sprinkler heads that had activated. The remaining fire was quickly extinguished by the crews. Fire personnel remained on scene for one hour for overhaul, salvage and investigation.

**Injuries:** None  
**Transported To:** N/A  
**Fatalities:** None  
**Total Time to Contain:** 5 minutes  
**Total Time to Control:** 30 minutes  
**Number of CTL Units and Personnel:** 5 units and 15 personnel  
**Automatic Aid/Mutual Aid Used:** None

**Investigation Status:** Remains under investigation.

**Confirmed by:** Miller/Akin  
(Investigation Group Supervisor)

**Prepared by** Battalion Chief Miller

KSCO fax# 475-2967  
Santa Cruz Sentinel fax#429-9620  
Mid-County Post fax# 476-5023  
KION fax# 754-1120

Register/Pajaronian fax# 761-7338  
Northern Calif. News fax 800-795-2925  
KSBW fax# 426-3897

cc: original to Admin. Assist.

Copies to: Operations A.C. & Admin. Staff